March 17, 2026

IFB FL 033126 - 2026 Transfer Switch Repair Project at Westfall Campus in Monroe County

A signed Addendum must be received with your proposal or within 3 business days of request by OPWDD. Failure to submit this signed Addendum as specified above may result in the bid being disqualified.

Addendum 1

Updated Bid Opening Date

1. On page 3, Section **3. Timetable of Proposal Due Dates**:

   Proposal Due Date – Bid Opening* 3:00 PM, 10 April 2026

2. On page 6, Section **13. Submission of Proposals**, Subsection **A. Submission Requirements**:

   (4) Bid Opening will be done via Microsoft Teams following standard formal bid opening procedures. If bidders wish to "attend", they may do so by calling: **1-518-801-9699 at 3:00 PM, 10 April 2026**. Bidders will be asked for a PHONE CONFERENCE ID. Enter Meeting ID **785 038 583 followed by the # sign.**

Updated Qualifications & Scope of Work

On page 18, Section **I. Detailed Specifications #6 replace with**:

6. The mechanical components of the switchgear must be troubleshot and repaired concurrently along with the PLC and HMI upgrade. The PLC logic cannot be tested in full UL compliance without also making repairs to the mechanical components of the switchgear.

   The Contractor will complete troubleshooting and repair of the mechanical switchgear with an approved Eaton certified technician or by Eaton Electrical Engineering Services. The Contractor will also complete full logic validation and safety verification, integrated mechanical and software commissioning, and creation of complete as-built documentation and CAD files to create a UL compliant system.

Please complete the confirmation below that you have received and reviewed the Addendum.

2026 Transfer Switch Repair Project at Westfall Campus in Monroe County
IFB FL 033126 Addendum 1

Confirmation of Addendum Received

_____
(Business Name)

_____ _____
(Signature) (Date)

_____ _____
(Print Name) (Title)

Respectfully,

Heather L Clausen, CMS 2
Contract Management Unit
(845) 877-6821 ext. 3625
(845) 877-3044 (fax)
heather.l.clausen@opwdd.ny.gov